

# Paris Community Unit School District No. 4



Danette Young, Superintendent  
Dan Lynch, Principal  
www.crestwood.k12.il.us

15601 US Hwy 150  
Paris, IL 61944  
Phone: (217)465-5391  
Fax: (217)466-1225

## Water Testing for Lead Content

All drinking water sources were tested for lead content on May 30, 2017. The results were received on June 27, 2017 and showed non-existent or extremely low levels of lead in all of the fifteen samples. Two samples were taken from each source. Every one of the thirty samples tested below the guidelines except for one. The one sample was drawn from the water fountain located in the north junior high wing. The first draw at this source showed a minimal amount of 7 parts per billion in the first draw and a non-existing amount in the second draw. Due to this showing, the drinking source was removed from service and a new unit was installed to replace the older unit. A new test was conducted on July 11, 2017. The results were received on July 19, 2017 showing non-existent or extremely low levels of lead from the water source.

For further information about lead in drinking water, please consult

<https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>